






SPACE TO REMOVE ELEMENT

FLANGE TYPE REQUIREMENTS	
P.C.D OF HOLES	
DIA OF R/F	
R/F THICKNESS	
NO OF HOLES	
DIA OF HOLES	

- ELEMENT AREA - 200cm²
- WEIGHT OF FILTER - 12 kg
- MAX WORKING PRESSURE - 16 bar (CAST IRON)
- TEST PRESSURE - 24 bar



ALL DIMENSIONS NOMINAL

UNLESS SPECIFIED GENERAL TOLERANCE 0 DEC PLACE +/- 1 1 DEC PLACE +/- 0.4 2 DEC PLACE +/- 1.0 ANGULAR +/- 2 Deg	APPROVED	MATERIAL	DESCRIPTION GENERAL ARRANGEMENT DN25 Fig Single Filter		
	DRAWN A.S.N.	OXFORD FILTRATION LIMITED			
MODIFICATION DRAIN WAS UNDER INLET	DATE 5/2/04	C 2003 This drawing and the design is the property of OXFORD FILTRATION LIMITED and may not be copied or used for any purpose other than that for which it was supplied unless expressly stated in writing.		DRG NO. 12086	ISS 2